



ADDENDUM NO. 1

TO: ALL VENDORS
FROM: Heidi DiFranco
SUBJECT: USCA-0221-HD – Marley Cooling Tower Refurbishment - Rebid
DATE: February 18, 2020

This Addendum No. 1 modifies the RFQ only in the manner and to the extent as stated herein.

Q & A's

1. Is there any information regarding the dimensions of the cold water basin?
 - a. The approximate proportions of the cold water basing are:
15'6" L x 7'6"W x 15"D

ITEM 1

Contractor shall be responsible for all dimensions and measurements.

BIDDER SHALL ACKNOWLEDGE RECIEPT OF ADDENDUM NO. 1 IN THE SPACE PROVIDED BELOW AND RETURN IT WITH THEIR BID RESPONSE. FAILURE TO DO SO MAY SUBJECT BID TO REJECTION.

Authorized Signature

Firm

Date